



## EXPANSION JOINT

Contraction joints shall be spaced 10' O.C.  
Concrete shall have five (5) sacks of cement  
per cubic yard of concrete.

### NOTE:

1. The Sidewalk Cross Slope Applies To The Driveway Inline With The Sidewalk Crossing It.
2. No water Meters Allowed In Sidewalks Or Driveways.
3. When A Manhole Or Water Valve Is Located In A Driveway Or Sidewalk, Public Works Must Inspect And Approve Before Code Enforcement Is Called [Phone (832) 595-3500] For Inspections.
4. No Welded Wire Mesh In Public Right Of Way.
5. Expansion Joints Shall Be Redwood Or Tar Felt Board.
6. Match Any Existing Flatwork.
7. Private Walkways\*, Patios\* And Stoops\* May Use Wire Mesh 6x6 #10 On Chairs.
8. Two (2) Dowels Minimum Shall Be Used In The Expansion Joints.
9. Sleeve Same Side Of Expansion Joint Through Out Project.
- \* Non Structural Support – Flatwork Only
10. All Form Boards And Expansion Joints Shall Be A Minimum Of Four (4 1/2") & Half Inches In Depth And Shall Rest On Subgrade.

THE CITY OF ROSENBERG, FORT BEND COUNTY, TEXAS  
DEPARTMENT OF PUBLIC WORKS

## *CONCRETE SIDEWALK NON SINGLE FAMILY RESIDENCE*

DESIGN: CAK	CAD: STAFF	SCALE: NTS	DATE: 12/14	DRAWING: P-101a
----------------	---------------	---------------	----------------	--------------------